

ADDENDUM www.jjr-us.com Page 1 of 1

Village of Dexter - Mill Creek Park - Phase 1	May 11, 2011	3
PROJECT	ISSUE DATE	ADDENDUM NO.
350094.004	P. Evanoff \ R. Abraham	
PROJECT NUMBER	PREPARED BY	

THIS ADDENDUM IS ISSUED BEFORE OPENING OF BIDS TO INFORM THE BIDDERS OF REVISIONS TO THE BIDDING DOCUMENTS AND IS HEREBY MADE A PART OF THE BIDDING DOCUMENTS.

ALL REQUIREMENTS CONTAINED IN THE BIDDING DOCUMENTS SHALL APPLY TO THIS ADDENDUM. THE GENERAL CHARACTER OF THE WORK CALLED FOR IN THIS ADDENDUM SHALL BE THE SAME AS ORIGINALLY SET FORTH IN THE APPLICABLE PORTIONS OF THE BIDDING DOCUMENTS FOR SIMILAR WORK, UNLESS OTHERWISE SPECIFIED HEREIN; AND ALL INCIDENTAL WORK NECESSITATED BY THIS ADDENDUM AS REQUIRED TO COMPLETE THE WORK SHALL BE INCLUDED IN THE BID, EVEN THOUGH NOT PARTICULARLY MENTIONED IN THIS ADDENDUM.

$\boxtimes$	NO DRAWINGS ARE ISSUED WITH THIS	S ADDENDUM.
	THE FOLLOWING DRAWINGS, DATED _	$\_$ , ARE ISSUED WITH THIS ADDENDUM AND FORM A PART HEREOF

## SPECIFICATIONS:

Item #1: Pre-cast Concrete Pavers: It has been brought to our attention that the existing pavers at the corner of Main and Jeffords Street are brick and not pre-cast concrete pavers. As such, the Village is allowing bidders to include brick pavers in their Base Bid price. The village will also allow the Bidders to use pre-cast concrete pavers as long as they match the existing "Bricks" at the corner of Main and Jeffords Streets.

When bidding brick materials the following shall apply: All requirements specified under 32 14 13, PRECAST CONCRETE UNIT PAVING (AGGREGATE BASE) shall apply except as noted below. Replace 2.1.C with the following:

## 2.1.C: BRICK PAVERS

- 1. Pavers shall be solid, wire cut or non-slip surface, extended from fine clay or shale specifically for exterior application.
- 2. Pavers shall conform to and pass all test requirements of ASM C 902 Class SX Type 1 application PX.
- 3. The manufacturer shall furnish independent laboratory test reports and certify that his material meets the above specifications. Comply with ASTM C 67.

## **END OF ADDENDUM**

p:\50094\004\admin\project management\specs\mitn addendum #2\mill-creek-park-addendum-3doc