



202 East Third Street  
Suite Two Hundred  
Royal Oak, MI 48067

tel 248 284 0611  
fax 248 284 0615  
mail@woldae.com

**To:** Prospective Bidders  
**From:** Wold Architects and Engineers  
**Date:** April 29, 2011  
**Comm. No:** 104004

**Subject:** Addendum No. 1 for Bidding Documents for the: Beck Education Center Improvements  
Redford, Michigan 48240

**BIDS DUE MAY 4, 2011 AT 2:00 P.M.**

This addendum forms a part of the Contract Documents dated April 20, 2011. Acknowledge receipt of this Addendum on the space provided on the Bid Form. Failure to do so may result in disqualification of Bid.

This Addendum consists of one (1) typed sheet:

**PROJECT MANUAL**

1. SPECIFICATION SECTION 4 01 20 TUCKPOINTING.
  - A. At Paragraph 2.02.A.1.b.1, delete "H. Hebron 65 Velour" and replace with, "Contractor to provide sample of brick match for architects review and approval prior to beginning work."

**DRAWINGS**

1. SHEET A1.01 FLOOR PLAN ELEVATIONS, SECTIONS, AND SCHEDULES.
  - A. Add the following note to key note "7", "Contractor to provide sample of brick to match for architects review and approval prior to beginning work.
  - B. Add the following note to louver elevations "L1" and "L2", "Contractor to provide sample of brick to match for architects review and approval prior to beginning work.
2. SHEET E1.02 ELECTRICAL NEW WORK PLAN – AREA 'B'.
  - A. Revise keyed note number 14 - 'Provide new photocell for undercanopy type 'HB' lighting control.'
  - B. Revise keyed note number 15 – Provide new Tork TW Series timeclock from local lighting circuit to parking lot light fixture. provide (2) new type 'HC' fixture with 1" c, 2#10 & 1#10g. location to be determined in the field. provide 200' of underground trenching with circuit in bid.'

END OF ADDENDUM #1